


## ASSEMBLY INSTRUCTION

Mounting bracket kit for easy suspension of CK contents:

1. 2 pcs mounting bracket
2. 4 pcs screws




The brackets can be mounted horizontally everywhere around the joint of the fan. For the right distance between the brackets, see the dimension table (B) and the distance from the joint to screw-hole (C).



Fan size	A +2	B +2	C +1
100	277	185	18
125	277	185	15
150 B	299	210	18
150 C	323	248	17
160 B	299	210	18
160 C	323	248	17
200	323	248	18
250	323	248	18
315	350	275	17



1. Mark the measure of **B** on the fan for the placement of the mounting brackets.



2. Mark the measure of **C**. Start from the joint of the fan.




3. Fasten the mounting brackets with the self-drilling screws.



## INSTALLATION INSTRUCTIONS

### Installation instructions for exhaust systems for duct fan,



1. Mark the measure of **A** on the wall or roof and then fasten the fan.




2. Put together the ducts and the fan.

### Installation with duct clamps for duct fan CK.

Duct clamp, type MK is made of pre-galvanized steel and is rubber-lined to seal connection and absorb vibrations. The clamp allows the fan to be easily removed for inspection and cleaning.

Available in sizes: Ø 80, 100, 125, 150, 160, 200, 250, 315, 355, 400, 500 and 630 mm.



3. Strap the duct clamps on each side of the fan with the screws.